



Annual Drinking Water Quality Report



NCMRWA North Havre CWD Leg MT0004720

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report please contact Jody Hellegaard at 406-945-4343. Public Participation Opportunities: You can attend meetings held on the 4th Tuesday of each month. Contact Jody Hellegaard for specific dates and times at 406-945-4343 or jody@ncmrwa.com.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information for NCMRWA North Havre CWD Leg
which is classified as a *Surface Water Purchaser* system

The source water assessment report for your water system provides additional information on your source water's susceptibility to contamination. To access this report please go to:
<https://deq.mt.gov/water/Programs/dw-sourcewater>

On the webpage scroll down and look under the subtitle "Montana Source Water Protection Viewer" and click the blue box with the same name. This will open the Montana Source Water Protection Viewer in a new tab on your internet browser. Once in there, click the grey box called "Source Water Reports" at the top.

NCMRWA North Havre CWD Leg utilizes the listed water sources below:

Water Source Name	Water Source Type
CONSECUTIVE CONNECTION FROM MT0000524	Consecutive Connection

Water Quality Test Results Definitions

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Avg: Regulatory compliance with some MCLs is based on running an annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A: Not applicable.

ND: Not detectable at testing limit.

Nephelometric Turbidity Unit (NTU) – Measure of the clarity or cloudiness of water. Turbidity more than 5 NTU is just noticeable to the typical person.

Picocuries per liter (pCi/L) – Measure of the radioactivity in water.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Secondary Maximum Contaminant Level (SMCL): SMCLs are established as guidelines to assist public water systems in managing their drinking water for aesthetic considerations, such as taste, color, and odor. These contaminants are not considered to present a risk to human health at the SMCL.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

The State of Montana DEQ requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one-year-old.

Lead and Copper								
Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1.3	1.3	0.814	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2025	0	15	11	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Contaminant Group: Disinfectants and Disinfection By-Products

Regulated Contaminants	Collection Year	Highest Level Detected	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2025	12	12 - 12	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	41	41 - 41	No goal for the total	80	ppb	N	By-product of drinking water disinfection.



Annual Drinking Water Quality Report



City of Havre MT0000524

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report please contact **Trevor Mork at (406) 265-4941 or Amanda Vaughn at (406) 265-5215**. Public Participation Opportunities: **If you want to learn more about our water, you can attend any of our regularly scheduled City Council meetings. The meetings are held on the first Monday of each month at 7:00 PM.**

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information for City of Havre
which is classified as a *Surface Water* system

The source water assessment report for your water system provides additional information on your source water's susceptibility to contamination. To access this report please go to:
<https://deq.mt.gov/water/Programs/dw-sourcewater>

On the webpage scroll down and look under the subtitle "Montana Source Water Protection Viewer" and click the blue box with the same name. This will open the Montana Source Water Protection Viewer in a new tab on your internet browser. Once in there, click the grey box called "Source Water Reports" at the top.

City of Havre utilizes the listed water sources below:

Water Source Name	Water Source Type
INTAKE MILK RIVER	Source Water Intake

Water Quality Test Results Definitions

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Avg: Regulatory compliance with some MCLs is based on running an annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A: Not applicable.

ND: Not detectable at testing limit.

Nephelometric Turbidity Unit (NTU) – Measure of the clarity or cloudiness of water. Turbidity more than 5 NTU is just noticeable to the typical person.

Picocuries per liter (pCi/L) – Measure of the radioactivity in water.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Secondary Maximum Contaminant Level (SMCL): SMCLs are established as guidelines to assist public water systems in managing their drinking water for aesthetic considerations, such as taste, color, and odor. These contaminants are not considered to present a risk to human health at the SMCL.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

The State of Montana DEQ requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one-year-old.

Lead and Copper								
Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1.3	1.3	1.09	2	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2025	0	15	3	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Contaminant Group: Disinfectants and Disinfection By-Products

Regulated Contaminants	Collection Year	Highest Level Detected	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2025	2.2	.04 – 2.2	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.

The chlorine highest level detected reflects the highest running annual average calculated each month during the CCR year. The range is the min/max of the monthly average during the CCR year.

Haloacetic Acids (HAA5)	2025	45	18 - 56	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	61	34 - 78	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Contaminant Group: Inorganic Contaminants

Regulated Contaminants	Collection Year	Highest Level Detected	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2020	0.09	.09 - .09	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2020	0.10	.1 - .1	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2025	0.06	.06 - .06	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

Turbidity

	Date	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement (NTU)	2025	1.00 NTU	0.44 NTU 17JUNE25 & 18AUG25	N	Soil runoff
Lowest monthly % meeting limit	2025	<i>At least 95%</i>	98.6% - APR	N	Soil runoff

Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

Unregulated Contaminants

Unregulated Contaminant	Collection Year	Highest Level Detected	Range of Levels	Units	Likely Source of Contamination
Lithium	2024/2025	17	12-17	µg/L	Groundwater Sources
PFAS	2024/2025	ND	0	µg/L	

Our water system has sampled for a series of unregulated contaminants as part of the EPA's Unregulated Contaminant Monitoring Rule (UCMR). Unregulated contaminants are those that don't yet have a drinking water standard set by the EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard in the future.

As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact: **Amanda Vaughn at (406) 265-5215**

Results can also be found by visiting the EPA's UCMR 5 Data Finder website:

<https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule-data-finder>



Annual Drinking Water Quality Report



North Havre County Water Dist MT0002988

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report please contact Mike Ladenburg at 406-390-8054.

Public Participation Opportunities: Monthly Board Meetings are held the third Tuesday of the month at 7:30 PM at the Wildhorse Fire Department fire hall.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information for North Havre County Water Dist
which is classified as a *Surface Water Purchaser* system

The source water assessment report for your water system provides additional information on your source water's susceptibility to contamination. To access this report please go to:
<https://deq.mt.gov/water/Programs/dw-sourcewater>

On the webpage scroll down and look under the subtitle "Montana Source Water Protection Viewer" and click the blue box with the same name. This will open the Montana Source Water Protection Viewer in a new tab on your internet browser. Once in there, click the grey box called "Source Water Reports" at the top.

North Havre County Water Dist utilizes the listed water sources below:

Water Source Name	Water Source Type
CONSECUTIVE CONNECTION FROM MT0004720	Consecutive Connection
CONNSECUTIVE CONNECTION FROM MT0004720	Consecutive Connection

Water Quality Test Results Definitions

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Avg: Regulatory compliance with some MCLs is based on running an annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A: Not applicable.

ND: Not detectable at testing limit.

Nephelometric Turbidity Unit (NTU) – Measure of the clarity or cloudiness of water. Turbidity more than 5 NTU is just noticeable to the typical person.

Picocuries per liter (pCi/L) – Measure of the radioactivity in water.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Secondary Maximum Contaminant Level (SMCL): SMCLs are established as guidelines to assist public water systems in managing their drinking water for aesthetic considerations, such as taste, color, and odor. These contaminants are not considered to present a risk to human health at the SMCL.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

The State of Montana DEQ requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one-year-old.

Lead and Copper								
Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09-11-2023	1.3	1.3	0.35	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09-11-2023	0	15	3	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Contaminant Group: Disinfectants and Disinfection By-Products

Regulated Contaminants	Collection Year	Highest Level Detected	Range of Levels	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2025	1.30	.61 - 1.43	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
<p>The chlorine highest level detected reflects the highest running annual average calculated each month during the CCR year. The range is the min/max of the monthly average during the CCR year.</p>								
Haloacetic Acids (HAA5)	2025	21	21 - 21	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	33	33 - 33	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Secondary Contaminants

Secondary Contaminant	Collection Year	Highest Level Detected	Range of Levels	SMCL	Units	Likely Source of Contamination and or Reason for Monitoring
TDS	2025	495	425 - 495	500	ppm	Erosion of natural deposits